



December 6, 2018

KCTCS – System Office Renovation

Copy Center Fit-up

PRE-BID MEETING (held on November 28, 2018)

300 North Main Street

Versailles, Kentucky

ADDENDUM #001

PURPOSE OF ADDENDUM:

The purpose of this Addendum is to clarify and/or revise the requirements of the construction documents produced by EOP Architects and Staggs & Fisher Consulting Engineers dated 11/12/18 for the above noted project.

The Contractor shall be governed by this Addendum insofar as it applies to the work of each Sub-Contractor.

- a. The Contractor shall acknowledge receipt of this Addendum on the Form of Proposal at the time his price bid is presented.

1.0 General Comments/Clarifications

- A. During the bidding process the Architect/Engineer does not require any formal request or nor does the Architect/Engineer review or approve proposed products or substitutions.

Please review the specifications and if you feel your product complies with the specifications, the Architect/Engineer encourage you to bid the project.

Once the project has been bid, then will the Architect/Engineer review the proposed product for compliance to the specifications.

2.0 Bid Date:

Clarification to Specification 001113, 1.2, A:

1. Bid Date: **December 13, 2018 (Thursday)**
2. Bid Time: 2:00pm, local time.
3. Location: City of Versailles, 196 South Main St., Versailles, KY 40383

3.0 BIDDERS QUESTIONS:

1. **Question:** Due to the location of remaining pipes near the deck, does the architect still expect the new cmu wall to extend full height to the deck.

Answer: All non-rated walls can extend to the underside of existing piping. They do not have to be cut in and around existing piping. But walls must extend above new ACT ceiling.

2. **Question:** Is there still an alternate for the a dedicated exhaust:

Answer: NO, omit Specification Section 012300.

3. **Question:** Light fixture schedule is missing from the documents.

Answer:

LF-1 LOW PROFILE 2'X4' LED FIXTURE. 2-3/8" DEPTH. CENTER BASKET. VOLUMETRIC DISTRIBUTION. DIE-FORMED HOUSING, PAINTED AFTER FABRICATION. HIGH PERFORMANCE IMPACT MODIFIED CURVED ACRYLIC DIFFUSER CONCEALS LEDS. HIGH REFLECTIVE REFLECTOR. 4800 LUMENS. 4000K. 0-10V DIMMING LED DRIVER, DIMMABLE TO 10%. INTEGRAL T-BAR CLIPS. UL LISTED FOR DAMP LOCATION AND IC RATED. 5 YEAR WARRANTY.

LITHONIA 2BLT 48L SERIES
WILLIAMS
COLUMBIA

LF-2 4' LED STRIPLIGHT. CODE-GAUGE, COLD-ROLLED STEEL COMPACT-DESIGN CHANNEL AND COVER. MEDIUM DIFFUSE LENS. TOOLLESS CHANNEL COVER. 5000 LUMENS. 4000K. 0-10V DIMMING LED DRIVER, DIMMABLE TO 10%. UL LISTED FOR DAMP LOCATION AND IC RATED. 5 YEAR WARRANTY. PENDANT MOUNT FIXTURE INSTALLATION.

LITHONIA ZL2N L48 SERIES
METALUX
DAY-BRITE

LF-EXIT IMPACT-RESISTANT, SCRATCH-RESISTANT, CORROSION-PROOF THERMOPLASTIC EXIT SIGN. INTERCHANGEABLE FACEPLATE AND BACK COVER. UNIVERSAL DIRECTIONAL CHEVRON REMOVABLE AND REINSERTABLE INSERTS. LED LAMPS. RED LETTERING. DUAL VOLTAGE INPUT. UNIVERSAL (TOP-, END-, OR BACK-) MOUNTING. UL LISTED FOR DAMP LOCATION. 5 YEAR WARRANTY.
LITHONIA LQM S SERIES

END OF ADDENDUM # 001