



December 6, 2018

## **KCTCS – System Office Renovation**

### **Copy Center Fit-up**

PRE-BID MEETING (held on November 28, 2018)

300 North Main Street

Versailles, Kentucky

---

# **ADDENDUM #001**

---

## **PURPOSE OF ADDENDUM:**

The purpose of this Addendum is to clarify and/or revise the requirements of the construction documents produced by EOP Architects and Staggs & Fisher Consulting Engineers dated 11/12/18 for the above noted project.

The Contractor shall be governed by this Addendum insofar as it applies to the work of each Sub-Contractor.

- a. The Contractor shall acknowledge receipt of this Addendum on the Form of Proposal at the time his price bid is presented.

## **1.0 General Comments/Clarifications**

- A. During the bidding process the Architect/Engineer does not require any formal request or nor does the Architect/Engineer review or approve proposed products or substitutions.

Please review the specifications and if you feel your product complies with the specifications, the Architect/Engineer encourage you to bid the project.

Once the project has been bid, then will the Architect/Engineer review the proposed product for compliance to the specifications.

## **2.0 Bid Date:**

Clarification to Specification 001113, 1.2, A:

1. Bid Date: **December 13, 2018 (Thursday)**
2. Bid Time: 2:00pm, local time.
3. Location: City of Versailles, 196 South Main St., Versailles, KY 40383

### **3.0 BIDDERS QUESTIONS:**

- 1. Question:** Due to the location of remaining pipes near the deck, does the architect still expect the new cmu wall to extend full height to the deck.

**Answer:** All non-rated walls can extend to the underside of existing piping. They do not have to be cut in and around existing piping. But walls must extend above new ACT ceiling.

- 2. Question:** Is there still an alternate for the a dedicated exhaust:

**Answer:** NO, omit Specification Section 012300.

- 3. Question:** Light fixture schedule is missing from the documents.

**Answer:**

**LF-1** LOW PROFILE 2'X4' LED FIXTURE. 2-3/8" DEPTH. CENTER BASKET. VOLUMETRIC DISTRIBUTION. DIE-FORMED HOUSING, PAINTED AFTER FABRICATION. HIGH PERFORMANCE IMPACT MODIFIED CURVED ACRYLIC DIFFUSER CONCEALS LEDS. HIGH REFLECTIVE REFLECTOR. 4800 LUMENS. 4000K. 0-10V DIMMING LED DRIVER, DIMMABLE TO 10%. INTEGRAL T-BAR CLIPS. UL LISTED FOR DAMP LOCATION AND IC RATED. 5 YEAR WARRANTY.

LITHONIA 2BLT 48L SERIES  
WILLIAMS  
COLUMBIA

**LF-2** 4' LED STRIPLIGHT. CODE-GAUGE, COLD-ROLLED STEEL COMPACT-DESIGN CHANNEL AND COVER. MEDIUM DIFFUSE LENS. TOOLLESS CHANNEL COVER. 5000 LUMENS. 4000K. 0-10V DIMMING LED DRIVER, DIMMABLE TO 10%. UL LISTED FOR DAMP LOCATION AND IC RATED. 5 YEAR WARRANTY. PENDANT MOUNT FIXTURE INSTALLATION.

LITHONIA ZL2N L48 SERIES  
METALUX  
DAY-BRITE

**LF-EXIT** IMPACT-RESISTANT, SCRATCH-RESISTANT, CORROSION-PROOF THERMOPLASTIC EXIT SIGN. INTERCHANGEABLE FACEPLATE AND BACK COVER. UNIVERSAL DIRECTIONAL CHEVRON REMOVABLE AND REINSERTABLE INSERTS. LED LAMPS. RED LETTERING. DUAL VOLTAGE INPUT. UNIVERSAL (TOP-, END-, OR BACK-) MOUNTING. UL LISTED FOR DAMP LOCATION. 5 YEAR WARRANTY.  
LITHONIA LQM S SERIES

**END OF ADDENDUM # 001**