



KENTUCKY COMMUNITY AND TECHNICAL COLLEGE SYSTEM

Invitation to Bid ADDENDUM #1

BID NO.: KCT-01089
ADDENDUM NO.: 1
BID ISSUE DATE: November 2, 2017
ADDENDUM DATE: November 17, 2017
OPENING DATE: November 27, 2017
TITLE: Water Fountain Removal/Installation

The following information is provided in response to questions submitted by potential Bidders:

1. Is there an estimated budget and start date for this project?
 - a. KCTCS is interested in conducting this project in the most economically feasible manner possible, which meets specifications. The start date would be as soon as possible.
2. For Chestnut Hall 3rd floor, where does electrical fall inside the wall?
 - a. There is an existing receptacle where the water fountain used to be on the 3rd floor near the southwest stairwell I pulled out the receptacle so I could get a better view of the box in the wall. The box has three conduits coming into it on the right side of the box through the block wall. There appears to be two other circuits in the box.
3. In Chestnut Hall, 1st floor, will it be the same height for the replacement?
 - a. Yes, if in accordance with plumbing code. If too high, please ensure compliance to the plumbing code.
4. Is a non-filtered option ok to quote due to space limitations?
 - a. Yes, we prefer non-filtered.
5. In Hartford Hall and Tech A, is the supplier allowed/expected to break out the block for fountain installation?
 - a. Yes, for any fountains this is required.
6. Who is responsible to put backing in to fill the void behind the fountains? If vendor, is a stainless steel sheet acceptable?
 - a. The vendor is expected to break block and replace backing. Stainless is acceptable.

7. In Hartford Hall and Tech A, the drains are at 33" and must be lowered. Is it possible to access the areas from the vents above or is it necessary break out blocking?
 - a. Breaking the block will be necessary; stainless steel is an acceptable backing.
8. In Hartford Hall, two water fountains were found, only 1 listed. Should the supplier replace both?
 - a. Yes, please bid to replace both

The timeline to submit additional questions has passed.

All other terms, conditions & specifications remained unchanged.

Bidders must acknowledge receipt of this and any addenda either with Invitation to Bid or by separate letter prior to award of contract. If by separate letter, the following information should be placed in the lower left hand corner of the envelope:

Bid No.: KCT-01089
Title: Water Fountain Removal/Installation
Opening Date: November 27, 2017 @ 4:00 PM EST

Name of Firm: _____

Signature: _____